USER MANUAL For Central Battery Systems - INV220V Series



Table of Contents

Part 1 : Overview Central Battery Systems	Page
1.1 Features	1
1.2 Technical Specifications	2
1.3 Indicators	3
1.4 Electrical Connector	4
Part 2 : Installation and Operation	
2.1 Battery Connection	5
2.2 Steps for Connecting the Input and Output	6
2.3 Device Initialization	7-9
2.4 Testing the Unit's Operability	10-11
Part 3 : Maintenance	
3.1 Device Maintenance	12
3.2 Initial Trouble Shooting	12
3.3 Important Note on Using the Unit	12
Part 4 : Terms for Warranty and Service	
4.1 Terms for Warranty and Service	13

Part 1 Overview Central Battery Systems

1.1 Features

Central Battery Systems by Inverter 220V is used to detect any abnormalities of the main power distribution system. In case of error or emergency, the unit will convert the battery voltage stored in the chemical form into the electric power and supply it to the inverter where the DC voltage from the battery will be converted into the AC voltage at 220VAC 50Hz to turn on the emergency light. On the other hand, when the main power distribution system resumes its normal operation, the unit will stop supplying the backup power and start recharging the battery for later use in case of another error or for the emergency light test.

Central Battery Systems by Inverter 220V Series has 2 function modes of operation.

- 1. MAINTAINED (Providing lighting constantly throughout the period when the AC line lights are in the normal status and when the AC Line lights are off.)
- 2. NON-MAINTAINED (Providing emergency lighting only when the AC line lights are off.)



1.2 Technical Specifications

M	lodel	INV220 Series									
Rated Cap (Wattage)	acity	200 300 400 500 700 1000 1200 1500 2000 2500 3000							4000		
Mode of O	perations	Ations Maintained and Non - Maintained									
Innut	Voltage	220-240VAC									
input	Frequency	50Hz									
Outrast	Voltage	AC220V ± 2% (Battery Mode)									
Frequency 50Hz ± 1% (Battery Mode)											
Output Wa	avefrom	Pure Sine Wave									
Terminal O	utput	2 Output									
Maximum (Wattage)	Load @ PF=1	F=1 200 300 400 500 700 1000 1200 1500 2000 2500 3000						4000			
Efficiency		>80%									
Battery Ty	ре	Sealed Lead - Acid Battery									
Battery Rat	ted Voltage	24V 48V									
Protection	IS	 Overload & Short circuit Battery Low voltage cut-off AC Input Low Voltage Protections 									
Operate of Temperatu	ire	10°C to 50°C									
Size L x W	x W x H (mm) 440x230x660 600x250x810 640x250x970 620x400x1200 620x600x1200					800x600x1500					

1.3 Indicators



No.	Symbol	Description	
1	AC. VOLTMETER	Indicating the input and output voltage.	
2	DC.VOLTMETER	Indicating the battery voltage.	
3	LED AC. Input	Indicating the status of the input voltage of 220-240VAC.	
4	LED DC. Input	Indicating the status of the battery power into the device.	
5	LED Operate	Indicating the operation status of the inverter unit.	
6	LED Testing	Indicating automatic battery discharge status.	
7	LED Charging	Indicating charging status.	
8	LED Battery Fail	Indicating the failure status of the battery.	
9	LED Charge Fail	Indicating the failure status of the battery charging.	

1.4 Electrical Connector

L	N	PE	L	N	PE	L	N	PE
AC.I	NPUT 22	OVAC	Martin (S	AINTAIN	ED month	NON	- MAINIA	AINED
	月下了						HC-1	
Chr	2	3 (6)		1 × 1	3 644		2	3 6
	STON 1		Sil Co		Collect		POP T	AR III
line of a		a commu						影曲
and the second	100	in the second		100	-	and the second se		10000

No.	Symbol	Description	
1	AC.INPUT 220VAC	Terminal for connecting power to the device	
2	MAINTAINED	Terminal Maintained for Continuous Power Supply Mode	
3	NON - MAINTAINED	Terminal Non-Maintained for Use in Emergency Power Supply Mode	



No.	Symbol	Description	
1	BATT	Circuit Breaker for Battery Operation On/Off	
2	AC.INPUT 220VAC	Circuit Breaker for On/Off Power Supply to the Device	
3	MAINTAINED	Circuit Breaker for On/Off Output Power	
4	NON - MAINTAINED	Circuit Breaker for On/Off Output Power	

Part 2 Installation and Operation

2.1 Battery Connection

Since the inverter operates at a voltage of 24 Volts and 48 Volts, for maximum efficiency the batteries are connected together to increase its voltage from 12 Volts to 24 and 48 Volts as shown in the diagram connecting the battery with the battery in the box connecting the positive (+) and negative (-) cables correctly.











Warning

- 1. Set all the breakers to Off prior to connecting the batteries.
- 2. Connect the cables to the correct battery terminal following the wiring diagram.
- 3. Do not short-circuit the battery terminals.
- 4. Check the Voltage of the battery after the connection to make sure if it is the desired 24 Volts or 48 Volts.

2.2 Steps for Connecting the Input and Output

1.) Test the readiness of the output load, for example, check for any short-circuits or if the total wattage exceeds the acceptable load. (Caution: The Output Line and Neutral circuit should be independent from other circuits otherwise damage could occur to the inverter.)

- 2.) When connecting to the Load Output in the circuit box there will be 2 outputs to choose from, which are
 - 2.1 Output Maintained. This connection will provide a constant 220Vac 50Hz current. This is suitable for uses that requires a constant current both during normal conditions and during power outages, for example, providing power for emergency exit signs without a built-in battery or lights that need to be constantly on such as lights installed in fire escapes or in parking lots.
 - 2.2 Output Non-Maintained. This connection will not provide a 220Vac 50Hz during normal conditions. The connection will only provide power during power outages. This connection is suitable for things such as emergency illumination lamps.



Caution: For the correct connection the Line should be connected into L, Neutral should be connected to N and Ground should be connected to PE The cables should be connected securely and no foreign objects should be in the circuit box that could potentially cause a short-circuit.

3.) Connect the Input cables to the Input 220VAC terminal inside the red frame inside the circuit box. The Line cable should be connected to the L terminal, the Neutral cable to the N terminal and the Ground cable to the PE terminal. The cables should be connected securely and no foreign objects should be in the circuit box that could potentially cause a short-circuit.



2.3 Device Initialization

1.) Turn on the Circuit Breaker BATT and the Circuit Breaker AC INPUT 220VAC (as indicated by the red frame). The device will begin charging the battery and enter a ready-to-use state. The front of the device will display the following status:



The display of device operation

Shows the current level at the Input to be

AC. VOLTMETER

about 220-240VAC.

DC. VOLTMETER Shows a battery Voltage at 24V or 48 V.

LED **AC. Input** The indicator showing that the unit is receiving a 220-240VAC current should be on.

LED **DC. Input** The indicator showing that the battery has been connected to the unit should be on.



LED **Charging** The indicator showing that the battery is charging. 2.) Set the Breaker AC.Input 220VAC to Off, the inverter will start operation as the same time set the Breaker MAINTAINED, NON-MAINTAINED to On (shown in the red marking), the unit should now be providing power to the load.



The display of device operation

AC. VOLTMETER

Shows the current level at the Output to be about 220VAC.

DC. VOLTMETER Shows a battery Voltage at 24V or 48 V.

LED DC. Input

The indicator showing that the battery has been connected to the unit should be on.

LED Operate

The indicator showing that the inverter is operational should be on.



- 3.) Test to see if the overall current level and load stability is at a normal level.
- 4.) Set the Breaker AC.Input to ON (shown in the red marking), after the unit should stop using the inverter and use the main power supply to provide power instead.



The display of device operation

AC. VOLTMETER Shows the current level at the Input to be about 220-240VAC.

DC. VOLTMETER Shows a battery Voltage at 24V or 48 V.

LED **AC. Input** The indicator showing that the unit is receiving a 220-240VAC current should be on.

LED **DC. Input** The indicator showing that the battery has been connected to the unit should be on.



LED **Charging** The indicator showing that the battery is charging.

2.4 Testing the Unit's Operability

1.) To test the unit, the user can set the Circuit Breaker AC Input 220VAC to OFF (shown in the red markings), the unit should start providing backup power to the emergency lights immediately.



- 2.) To stop the test, the user can set the Circuit Breaker AC Input 220VAC back to ON. The inverter should stop operating and the unit should return to standby mode.
- 3.) The unit has a built-in self-testing system that will perform 30 minutes self-tests every 30 days. This self-test system should start working once a current from AC. Input is provided to the unit.

The display of device operation

AC. VOLTMETER Shows the current level at the Input to be about 220-240VAC.

DC. VOLTMETER Shows a battery Voltage at 24V or 48 V.

LED **AC. Input** The indicator showing that the unit is receiving a 220-240VAC current should be on.

LED DC. Input

The indicator showing that the battery has been connected to the unit should be on.

LED Testing

The indicator showing that the unit automatically testing itself.



4.) If during the self-tests the battery is found to be faulty and cannot hold a charge or less charge that normal the unit will show a "Battery Fail" warning.

The display of device operation

AC. VOLTMETER

Shows the current level at the Input to be about 220-240VAC.

DC. VOLTMETER Shows a battery Voltage at 24V or 48 V.

LED **AC. Input** The indicator showing that the unit is receiving a 220-240VAC current should be on.

LED **DC. Input** The indicator showing that the battery has been connected to the unit should be on.



LED **Battery Fail** An LED will blink 3 times every 15 seconds to indicate that the fail battery.

Note: You can reset the alert by turning off and on the Circuit Breaker AC INPUT 220VAC and Circuit Breaker BATT.

5.) In the event that there is an abnormality in the battery charging system, such as over-charging voltage, inability to charge, and charging for more than 24 hours, the unit will display the "Charging Fail" status.

The display of device operation



LED **Charge Fail** An LED will blink 4 times every 15 seconds to indicate that there is a problem charging the battery

Note: You can reset the alert by turning off and on the Circuit Breaker AC INPUT 220VAC and Circuit Breaker BATT.

Part 3 Maintenance

3.1 Device Maintenance

- 1.) Keep ventilation fan of the unit clean.
- 2.) The unit has an Automatic testing system, automatically enabling 30 minute test every 30 days. If your unit does not have a self-test system you should manually test the unit once a month for 30 minutes to make sure the unit is fully operational and to help extend the life of the battery.

3.2 Initial Trouble Shooting

Cause	Problem	What to do
- 220-240 VAC Power not getting to the unit.	 The power socket might not have any power. Circuit Breaker AC. Input is in the OFF status. 	 Check to make sure that the power socket of the home or building is providing a 220VAC current. Check to make sure that theCircuit Breaker AC. Input is in the ON position.
- The Backup power supply of the unit has failed.	 Circuit Breaker DC. Battery is in the OFF status. Circuit Breaker AC. Output is in the OFF status. 	 Check to make sure that the Circuit Breaker DC. Battery is in the ON position. Check to make sure that the Circuit Breaker AC. Output is in the ON position.
- Emergency light only turns on for a short time after the power went out.	- The battery is not fully charged. - The battery has degraded.	 Fully charge the battery. Contact customer service to replace the battery.

3.3 Important Note on Using the Unit

- 1.) Please read the manual carefully before installation and operation
- 2.) Installation area should be good ventilation.
- 3.) Do not connect the battery in reverse polarity.
- 4.) Check the power load before installing the unit.
- 5.) Do not use with the power load when it is in an unstable condition.
- 6.) The power load must be an emergency light only. Do not use with the other power load that is not approved by the manufacturer.
- 7.) The unit should be stored in temperatures under 25 Degree Celsius and the battery should be charged every 3 month to maintain its operational life.

Part 4 Terms for Warranty and Service

4.1 Terms for Warranty and Service

- 1. The Warranty will only be covered if the customer fills in the "warranty registration form" and mail the return part back to the company within 7 days from the day of purchase. If this is not carried out the warranty will be considered void.
- 2. The warranty only covers the unit's internal parts. The conditions and durations for the warranty of each part is as specified and the duration of the warranty is calculated from the date of purchase.
- 3. Please show your warranty card every time you contact our service center or the dealer you purchased the product from.
- 4. Products that fall into the following category are considered not covered by the warranty.
 - 4.1 The product was used in a way not specified in the manual.
 - 4.2 The product was used with accessories not meeting the required specifications specified in the manual.
 - 4.3 The product seems to have been damaged from being dropped or from strong impact, for example, the parts are loose, dented, scrapped or misshapen.
 - 4.4 The product has been repaired or modified by personnel not authorized by our company.
 - 4.5 The Warranty Void sticker is torn or removed.
 - 4.6 The product is damaged from careless use or incorrect maintenance, for example, the battery is swollen from overcharging, quick charging was used on the battery, the battery terminals have been short-circuited, the unit was used until the battery was completely discharged and not recharged immediately, the product was stored for long periods until the Battery Checker warning activates and still it is not plugged-in to charge or taking the battery to normal temperature conditions and not recharging it every 1 month.
 - 4.7 The product was stored in an unsuitable environment, for example, a location with moisture or water vapor.
 - 4.8 The product was supplied with a faulty AC power supply such as electrical overvoltage, electrical current surges, or lightning strikes entering the AC power line.
 - 4.9 Damages from natural causes such as fire, being summered in fluids, humidity, chemicals or force majeure.
 - 4.10 Damages from insects or animals.

Note : Please read the manual carefully before installation and operation to understand how to properly operate the unit.

Contact us

Head Office 2915-2917 Ladprao Road, Klongjan, Bangkapi, Bangkok 10240 phone 02 378 1034-5 fax 02 370 1672



© Ison Import-Export Co.,Ltd. All Right Reserved. Specifications subject to change without notice.